

GENERAL NOTES  
(APPLY THIS SHEET ONLY)

- BRANCH CIRCUIT CONDUCTORS SHALL NOT BE SMALLER THAN NO. 12 AND WHEN THE HOMERUN FROM CENTER OF LOAD EXCEEDS 100'-0" FOR 120 VOLTS AND 200'-0" FOR 277 VOLTS, THE CONDUCTORS FROM HOMERUN OUTLET TO PANEL SHALL BE #10 IN 3/4"C.
- ALL DEVICES SHALL BE CONSIDERED NEW UNLESS NOTED OTHERWISE. REFER TO LIGHT FIXTURE SCHEDULE ON SHEET E0.01 FOR LIGHT FIXTURE SPECIFICATIONS.
- COORDINATE SITE LIGHTING ELECTRICAL ROUTING WITH CIVIL ENGINEER AND ALL OTHER TRADES.

LEGEND NOTES  
(APPLY THIS SHEET ONLY)

- EXISTING TRANSFORMER TO REMAIN AS-IS. VERIFY EXACT LOCATION, ORIENTATION, AND DIMENSIONS WITH POWER COMPANY.
- ROUGH LOCATION OF EXISTING FIXTURE. FIXTURE TO REMAIN AS-IS UNLESS NOTED OTHERWISE. COORDINATE EXACT LOCATION WITH CIVIL DRAWINGS FOR EXACT FIXTURE LOCATION. CIRCUITRY TO REMAIN AS-IS UNLESS NOTED OTHERWISE.
- PROVIDE AND INSTALL (1) 2" E.C. WITH PULL STRING TO THE EXISTING BUILDING TELEPHONE BACKBOARD. MAINTAIN INDUSTRY STANDARD RECOMMENDED CLEARANCES FROM LIGHT FIXTURES ETC. NO MORE THAN TWO (2) 90 DEGREES BENDS BETWEEN PULL POINTS. PROVIDE PULL BOXES AS REQUIRED.
- REFER TO RISER DIAGRAM FOR MORE INFORMATION.



Copyright (c) 2026 Praxis3, LLC  
All reports, plans, specifications, computer files, field data, notes and other documents and instruments prepared by Praxis3 and retain all copyright law, statutory and other reserved rights, including copyright therein.  
This drawing may not be reproduced in whole or in part without written permission of Praxis3. It is to be returned upon request. Stamps as noted are valid on the original drawing.

Rev	Date	Comments
	05/22/2026	Permit & Bid Set

Client:

Fannin County


Project Number: 24184

Project Name:

Fannin County Rec  
Center - Phase I

580 Winding Drive  
Blue Ridge, Georgia 30513

Key Plan:



Sheet Title:

SITE PLAN -  
ELECTRICAL

Sheet Number:

E002-I